

CERTIFICATE OF COMPLIANCE

Certificate Number 20130612-E347373
Report Reference E347373-20130612
Issue Date 2013-JUNE-12

Issued to: PURGE SOLUTIONS
SUITE C
12454 GALVESTON RD
WEBSTER TX 77598


This is to certify that representative samples of PURGING AND PRESSURIZING CONTROLS AND ACCESSORIES FOR USE IN HAZARDOUS LOCATIONS
See addendum for models.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 913, Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations
ANSI/ISA 12.12.01, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
NFPA 496, Purged and Pressurized Enclosures for Electrical Equipment
UL 508, Industrial Control Equipment

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle: with the word "CLASSIFIED"  (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and the product category name (product identity) as indicated in the appropriate UL Directory.

Look for the UL Classification Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus




CERTIFICATE OF COMPLIANCE

Certificate Number 20130612-E347373
Report Reference E347373-20130612
Issue Date 2013-JUNE-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Purge / Pressurization Indicator, Type Z, for use in hazardous locations, Models PSCZ-XX and PSCZ-XXX for Class I, Division 2, Groups A, B, C, and D, Class II, Division 2, Groups F, and G, Class III Hazardous Locations.

Purge/Pressurization Indicator, Type Y for use in hazardous locations, Models PSCY-XX and PSCY-XXX for Class I, Division 1, Groups A, B, C, and D, Class II, Division 1, Groups F and G, Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. DO-11108-C.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

